	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 772.0
Issue Date: 12/13/2010
Revision Date: 4/5/2016
Expiration Date: 11/15/2020
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: 5470/5570 Sliding Glass Door w/ & w/o Corner Operator Type: SD Config: H/J/S/Ast/Clip/All/4-1/16SR, GS-3/16 Temp IG Max Width: 203 Max Height: 96
-------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG80 5144x2438 (99x203x96)-SD
--------------------------------------------------------------	------------------------------------------------------------------


Qualifying Test Information:	
Test Report No:	FTL-6369
Test Report Expiration:	11/15/2020

Authorized Signature:



Digitally signed by
Steven Urich
Date: 2016.04.06
11:22:12 -04'00'

Keystone Certifications, Inc.
564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 770.0
Issue Date: 12/13/2010
Revision Date: 4/5/2016
Expiration Date: 11/11/2020
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: 5470/5570 Impact SGD w & w/o Corner Operator Type: SD Config: H/J/S/Ast/Clip/All/SR, GS-3/16 Temp IG Max Width: 203 Max Height: 96
-------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG60 2515x5144x2438 (99x203x96)-SD
--------------------------------------------------------------	-----------------------------------------------------------------------

Qualifying Test Information:	
Test Report No:	FTL-6367/6368/8545
Test Report Expiration:	11/11/2020


Authorized Signature:



Digitally signed by
Steven Urich
Date: 2016.04.06
11:20:10 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 771.0
Issue Date: 12/13/2010
Revision Date: 4/5/2016
Expiration Date: 11/21/2020
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: 5470 Sliding Glass Door w & w/o Corner Operator Type: SD Config: H/J/S/Clip/All/3-1/2SR, GS-3/16 Temp IG Max Width: 241 Max Height: 96
-------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG60 6121x2438 (241x96)-SD
--------------------------------------------------------------	---------------------------------------------------------------

Qualifying Test Information:	
Test Report No:	FTL-6370
Test Report Expiration:	11/21/2020


Authorized Signature:



Digitally signed by
Steven Urich
Date: 2016.04.06
11:29:34 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 774.0
Issue Date: 12/15/2010
Revision Date: 4/5/2016
Expiration Date: 11/23/2020
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: 5570 Impact SGD w & w/o Corner Operator Type: SD Config: H/J/S/Ast/Clip/All/3-1/2SR, GS-3/16 Temp IG Max Width: 203 Max Height: 120
-------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG60 5144x3048 (203x120) Neg DP=65
--------------------------------------------------------------	-----------------------------------------------------------------------

Qualifying Test Information:	
Test Report No:	FTL-6371
Test Report Expiration:	11/23/2020

Authorized Signature:



Digitally signed by
Steven Urich
Date: 2016.04.06
11:26:58 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501