	Document Title: <b>Impact Performance Certification Authorization Report</b>	Doc No: <b>FRM B1-43</b>		
		Rev No: 4	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 299  
Issue Date: 1/16/2015  
Revision Date: 10/10/2018  
Expiration Date: 1/9/2022  
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com).

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: CA5540 PVC Impact Casement Operator Type: C Config: All/Stub, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 75 Corresponding Structural CARs: 190-1059.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+-50, 36x75

Qualifying Test Information:	
Test Report No:	FTL-8082
Test Report Expiration:	1/9/2022

Authorized Signature:



2018.10.11  
13:26:24 -04'00'

**Keystone Certifications, Inc.**  
145 Limekiln Rd., Suite 100B  
New Cumberland, Pennsylvania 17070  
Phone: 717-932-8500  
Fax: 717-932-8501

	Document Title:	Doc No: <b>FRM B1-43</b>	
	<p align="center"><b>Impact Performance Certification Authorization Report</b></p>	Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 501  
 Issue Date: 1/16/2015  
 Revision Date: 10/10/2018  
 Expiration Date: 1/9/2022  
 Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com).

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: CA5540 PVC Impact Casement Operator Type: C Config: All/Snub, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 84 Corresponding Structural CARs: 190-1060.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+65/-70, 36x84


Qualifying Test Information:	
Test Report No:	FTL-8084/8085/8086
Test Report Expiration:	1/9/2022

**Authorized Signature:**



2018.10.11  
 13:27:28 -04'00'

**Keystone Certifications, Inc.**  
 145 Limekiln Rd., Suite 100B  
 New Cumberland, Pennsylvania 17070  
 Phone: 717-932-8500  
 Fax: 717-932-8501

	Document Title: <b>Structural Performance  Certification  Authorization Report</b>	Doc No: <b>FRM B1-02</b>	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1059.0  
Issue Date: 1/16/2015  
Revision Date: 10/10/2018  
Expiration Date: 1/9/2022  
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com).

<b>Licensee Information:</b> PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	<b>Product Information:</b> Model: CA5540 PVC Impact Casement Operator Type: C Config: All/Snub, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 75
---	---

<b>Referenced Standard:</b> AAMA/WDMA/CSA 101/I.S.2/A440-11	<b>Product Rating:</b> Class LC-PG50 914x1905 (36x75)-Type C WTP=9.75
--	--

<b>Qualifying Test Information:</b>	
Test Report No:	FTL-8081
Test Report Expiration:	1/9/2022

**Authorized Signature:**



2018.10.11  
12:32:45 -04'00'

**Keystone Certifications, Inc.**  
145 Limekiln Rd. Suite 100B  
New Cumberland, Pennsylvania 17070  
Phone: 717-932-8500  
Fax: 717-932-8501

	Document Title: <b>Structural Performance  Certification  Authorization Report</b>	Doc No: <b>FRM B1-02</b>	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1060.0  
Issue Date: 1/16/2015  
Revision Date: 10/10/2018  
Expiration Date: 1/9/2022  
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com).

<b>Licensee Information:</b> PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	<b>Product Information:</b> Model: CA5540 PVC Impact Casement Operator Type: C Config: All/Snub, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 84
---	---

<b>Referenced Standard:</b> AAMA/WDMA/CSA 101/I.S.2/A440-11	<b>Product Rating:</b> Class LC-PG65 914x2134 (36x84)-Type C Neg DP=70
--	---

<b>Qualifying Test Information:</b>	
Test Report No:	FTL-8083
Test Report Expiration:	1/9/2022

**Authorized Signature:**



2018.10.11  
12:33:23 -04'00'

**Keystone Certifications, Inc.**  
145 Limekiln Rd. Suite 100B  
New Cumberland, Pennsylvania 17070  
Phone: 717-932-8500  
Fax: 717-932-8501